

Date of Issue – 19 October 2017

EU DECLARATION OF CONFORMITY

1. Object of the Declaration of Conformity:

Product Family: XP95 Interfaces

Part Number	Brand	Product Description
55000-182	XP95 Interfaces	XP95 DIN Rail Sounder Control Unit 5 Amperes
55000-802	XP95 Interfaces	XP95 DIN Rail Dual Isolator
55000-803	XP95 Interfaces	XP95 DIN Rail Input/Output Unit
55000-812	XP95 Interfaces	XP95 DIN Rail Zone Monitor with Isolator
55000-822	XP95 Interfaces	XP95 DIN Rail Switch Monitor
55000-843	XP95 Interfaces	XP95 Switch Monitor with Isolator
55000-845	XP95 Interfaces	XP95 Zone Monitor Unit with Isolator
55000-847	XP95 Interfaces	XP95 Input/Output Unit with Isolator
55000-852	XP95 Interfaces	XP95 Sounder Control Unit with Isolator
55000-875	XP95 Interfaces	XP95 Mains Input/Output Unit

2. These products are manufactured at the premises of Apollo Fire Detectors Limited, 36 Brookside Road, Havant, Hampshire, England PO9 1JR.
3. This declaration is issued under the sole responsibility of the manufacturer.
4. The object of the declaration described above is in conformity with the relevant Union harmonization legislation:

2014/30/EU EMC Directive
2011/65/EU Restriction of the use of certain hazardous substances in electrical and electronic equipment (RoHS)

5. References to the relevant harmonized standards used or references to the specifications in relation to which conformity is declared:

BS EN 61000-6-3: 2007+A1: Electromagnetic compatibility (EMC). Generic standards.
2011 Emission standard for residential, commercial and light-industrial environments

DN20v1

A HALMA COMPANY



Assessed to ISO 9001:2008
LPCB Cert No. 010

Certificate No. 010
See www.RedBookLive.com

Assessed to ISO 14001:2004
Certificate number EMS 010

Apollo Fire Detectors Limited

36 Brookside Road, Havant, Hampshire, PO9 1JR, UK
t +44 (0)23 9249 2412 f +44 (0)23 9249 2754 e sales@apollo-fire.co.uk

www.apollo-fire.co.uk

Apollo Fire Detectors Ltd. Registered in England No. 1483208
Registered Office: 36 Brookside Road, Havant, Hampshire, PO9 1JR VAT Registration No. GB339 055354


BS EN 50130-4:2011+A1:
2014

Alarm systems. Electromagnetic compatibility. Product family
standard: Immunity requirements for components of fire,
intruder, hold up, CCTV, access control and social alarm
systems

6. References to the applicable test reports:

TE 245499, TE 252733, TE 245059, LSR4146, LSR 3720, LSR3087, TR4251, TR4252, TR4253, TR4254, TR4255

This declaration is made for and on behalf of Apollo Fire Detectors by the Technical Director, Mr. Karl Westhead, who has been designated as the responsible person for the purpose of the Regulations.

Signature ..  Mr. Karl Westhead – Technical Director

