

Declaration of Performance No. 20-8006-360-0002

Declaration of Performance according to the Construction Products Regulation EU No. 305/2011

1. Unique identification code of the product type	Brand(s): ARITECH Model(s): DT654 SERIES 65 Conventional Class A1R Heat Detector DT655 SERIES 65 Conventional Class BR Heat Detector
2. Intended use/es	Heat Point detectors according to EN 54-5
3. Manufacturer	Apollo Fire Detectors Limited 36 Brookside Road, Havant, Hampshire PO9 1JR, UNITED KINGDOM
4. Authorized representative	UTC Fire & Security B.V. Kelvinstraat 7, NL-6003 DH Weert, THE NETHERLANDS
5. System or systems of AVCP	System 1
6a. Harmonised standard/s:	EN 54-5:2000 + A1:2002
Notified body/ies:	0832 – BRE GLOBAL LIMITED
6b. European Assessment Document: European Technical Assessment: Technical Assessment Body: Notified body/ies:	N.A.

7. Declared performances:

Heat detectors – Point detectors EN 54-5


Essential characteristics	Performance	Harmonized technical specification
Nominal activation conditions / Sensitivity, Response delay (response time) and Performance under fire conditions 4.2, 4.3, 5.2 to 5.6, 5.8, 6.1 (Suffix S detectors only) 6.2 (Suffix R detectors only)	PASS -- --	EN 54-5:2000 + A1:2002 -- --
Operational reliability 4.4 to 4.11	PASS	EN 54-5:2000 + A1:2002
Tolerance to supply voltage 5.7	PASS	EN 54-5:2000 + A1:2002
Durability of operational reliability and response delay; temperature resistance 5.9, 5.10	PASS --	EN 54-5:2000 + A1:2002 --
Durability of operational reliability, Vibration resistance 5.14 to 5.17	PASS	EN 54-5:2000 + A1:2002
Durability of operational reliability, Humidity resistance 5.11 to 5.12	PASS	EN 54-5:2000 + A1:2002
Durability of operational reliability, Corrosion resistance 5.13	PASS	EN 54-5:2000 + A1:2002
Durability of operational reliability, Electrical stability 5.18	PASS	EN 54-5:2000 + A1:2002

8. Appropriate Technical Documentation and/or Specific Technical Documentation:

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by::

Name: José María Méndez Seguí.
Function: Technology Manager , EMEA
Place: Verge de Guadalupe 3, Esplugues de Llobregat
08950, Barcelona, Spain



At: Esplugues de Llobregat

On: Jun 07th, 2017

Regulation (EU) No. 305/2011 CPR Supplementary CE marking information



Identification of the Certification Body: 0832

Manufacturer: **Apollo Fire Detectors Limited**

36 Brookside Road, Havant, Hampshire PO9 1JR, UNITED KINGDOM

Last two digits of year CE mark was first placed: 17

Declaration of Performance (DoP) Number: 20-8006-360-0002

EN 54-5:2000 + A1:2002

Unique identification of product type: See the product label for the product documentation part number and revision.

Intended use: See DoP point 2.

Essential characteristics: See DoP point 7.

EN: Get this document in your language from: / BG: Вземете този документ на български език от / CZ: Získat tento dokument ve Vašem jazyce od: / DA: Få dette dokument på dit sprog fra: / NL: Krijg dit document in uw taal van: / ET: Dokumendi eestikeelse versiooni leiata siit: / ES: Obtenga este documento en su idioma de: / FI: Hanki tämä asiakirja kielelläsi: / FR: Obtenez ce document dans votre langue de: / DE: Sie erhalte das Dokument in Ihrer Sprache von: / EL: Μπορείτε να παραλάβετε το έγγραφο στη γλώσσα σας από: / HU: A dokumentum megvásárolható a kívánt nyelven: / IT: Ottieni questo documento nella tua lingua da: / LV: Iegūstiet šo dokumentu savā valodā no: / LT: Gauti šį dokumentą jūsų kalba iš: / PL: Pobierz ten dokument w swoim języku z: / PT: Obtenha este documento no seu idioma a partir: / RO: Puteti obtine acest document in limba dumneavoastra de la: / SK: Získať tento dokument vo Vašom jazyku od: / SL: Spravi ta dokument v vašem jeziku od: / SV: Få detta dokument på ditt språk från:

<http://www.utcssecurityproducts.eu/dop/>

DoP.Requests@fs.utc.com

© 2017 UTC Fire & Security. All rights reserved