

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00248

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

Product(s): Ziton Radio Hub
(refer to attached appendix for details and conditions)

**Placed on the market
under the name or trade mark of:** UTC Fire & Security B.V.
Kelvinstraat 7
6003 DH Weert
The Netherlands

**and produced in the
manufacturing plant(s):** EMS Security Group Limited (SG-15557)
Technology House, Sea Street
Herne Bay, Kent, CT6 8JZ
United Kingdom

Intended use: Fire Safety

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

EN 54-25:2008+AC:2012
EN 54-18:2005+AC:2007

Under System 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

This certificate was first issued under **0359-CPR-00248** on **2013-09-30** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Notified Body

0905

Certification Manager: Dipl.-Ing. Roland Heine

Signature:



Date Issue: 2020-10-09
Issue: 1

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Intertek Deutschland GmbH, Stangenstraße 1, 70771 Leinfelden-Echterdingen
Tel.: +49 711 27311-0 E-Mail: nb0905@intertek.com Web: www.intertek.de

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00248

APPENDIX TO: Certificate of Constancy of Performance 0905-CPR-00248

The details and conditions of use for the Ziton Radio Hub , placed on the market under the name or trade mark of:

UTC Fire & Security B.V.
Kelvinstraat 7
6003 DH Weert
The Netherlands

To be used in accordance with the supplier's installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

Products compliant with EN 54-25:2008+AC:2012 and EN 54-18:2005+AC:2007:

Model	Manufacturing Location	Description
ZPR868-H	SG-15557	Ziton Radio Hub - 4 Loop vwith Wire Aerials
ZPR868-HS	SG-15557	Ziton Radio Hub - 4 Loop vwith SMA Aerials

Conditions of use:

Suitable for indoor applications

General Notes:

1. Evaluated under Intertek project number 101092772.
2. No CE or other type approval is made or inferred outside of the attestation of conformity and the product performance as stipulated on this certificate.

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Intertek Deutschland GmbH, Stangenstraße 1, 70771 Leinfelden-Echterdingen
Tel.: +49 711 27311-0 E-Mail: nb0905@intertek.com Web: www.intertek.de

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00248

APPENDIX TO: Certificate of Constancy of Performance 0905-CPR-00248

Table of performance for EN 54-25:2008+AC:2012 Harmonised technical specification			
Essential characteristics	Performance	Clauses	Notes
Performance parameters under fire conditions	Pass	4.1 4.2.2 5.2 8.3.7	a
Response delay (response time to fire)	Pass	8.2.3 8.2.6	b
Operational reliability	Pass	4.2.1, 4.2.3 to 4.2.7, 5.3, 5.4, 6, 7, 8.2.2, 8.2.4, 8.2.5, 8.2.7, 8.2.8(d), 8.2.9, 8.3.1, 8.3.2, 8.3.3, 8.3.5, 8.3.6	d
Durability of operational reliability; Temperature resistance	Pass	8.3.9 8.3.10 8.3.11	d d
Durability of operational reliability; Vibration resistance	Pass	8.3.16 8.3.17 to 8.3.19	c
Durability of operational reliability; Humidity resistance	Pass	8.3.12 8.3.13 8.3.14	d e
Durability of operational reliability; Corrosion resistance	Pass	8.3.15	c
Durability of operational reliability; Electrical stability	Pass	8.3.20	
Notes: a The products covered by this standard are assumed to enter the alarm condition in an event of fire, before the fire becomes so large as to affect their functioning. There is therefore no requirement to function when exposed to direct attack from fire. b Only applicable to components required to indicate loss of communication or to transmit this information to the CIE. c Not applicable for CIE. d Not applicable for CIE and smoke detectors. e Only applicable for CIE and smoke detectors.			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Intertek Deutschland GmbH, Stangenstraße 1, 70771 Leinfelden-Echterdingen
Tel.: +49 711 27311-0 E-Mail: nb0905@intertek.com Web: www.intertek.de

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00248

APPENDIX TO: Certificate of Constancy of Performance 0905-CPR-00248

Table of performance for EN 54-18:2005+AC:2007 Harmonised technical specification			
Essential characteristics	Performance	Clauses	Notes
Response delay (response time)	-	5.2	a
Performance under fire conditions	Pass	5.1.4	
Operational reliability	Pass	5.1.4	
Durability of operational reliability; Temperature resistance	Pass	5.3, 5.4	
Durability of operational reliability; Vibration resistance	Pass	5.8 to 5.11	
Durability of operational reliability; Humidity resistance	Pass	5.5, 5.6	
Durability of operational reliability; Corrosion resistance	Pass	5.7	
Durability of operational reliability; Electrical stability	Pass	5.2, 5.12	
Notes: a Response delays may not be a function of the input/output device, in which case no assessment is made as part of this standard.			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Intertek Deutschland GmbH, Stangenstraße 1, 70771 Leinfelden-Echterdingen
Tel.: +49 711 27311-0 E-Mail: nb0905@intertek.com Web: www.intertek.de