

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited DCU Alpha, Old Finglas Road Glasnevin, Dublin, D11 KXN4 Ireland T: +353 (0) 18824344 E: enquiries@breglobalireland.ie www.breglobalireland.ie

Certificate of constancy of performance 2831-CPR-F0520

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

2X-F2 Two Loop Intelligent Analogue Addressable Control and Indicating Equipment (For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade

mark of:

Carrier Fire & Security B.V.

Kelvinstraat 7 NL-6003 DH

Weert

Netherlands

and produced in the manufacturing plant(s):

Carrier Manufacturing Poland Spółka Z o.o.

ul. Kolejowa 24

Ropczyce 39-100

Poland

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-2:1997 + A1:2006 - Control and indicating equipment

EN 54-4:1997 + A1:2002 + A2:2006 - Power supply equipment

EN 54-21:2006 - Alarm Transmission and Fault Warning Routing Equipment

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 23 October 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Date of First Issue: 23 October 2019

E Mattie-Suleiman, Certification Engineer Date of Issue: 14 March 2023

On behalf of BRE Global Assurance (Ireland) Limited Issue number 03

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.

BF1938i Rev.1.0 Page 1 of 6 © BRE Global Assurance (Ireland) Limited, 2023



Notified Body No. 2831

BRE Global Assurance (Ireland) Limited DCU Alpha, Old Finglas Road Glasnevin, Dublin, D11 KXN4 Ireland

T: +353 (0) 18824344 E: enquiries@breglobalireland.ie www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F0520

2X-F2 Two Loop Intelligent Analogue Addressable Control and Indicating Equipment

The details and conditions of use for the 2X-F2 two loop intelligent analogue addressable control and indicating equipment placed on the market by Carrier Fire & Security B.V., Kelvinstraat, NL-6003 DH, Weert, The Netherlands are:

To be used in accordance with the suppliers installations instructions and in conjunctions with the following bases ancillaries, sounder tones and sensitivity settings (where applicable):

2X-F2 Intelligent Analogue Addressable Control and Indicating Equipment with User Interface - 2 Loop **2X-F2-PRT** Intelligent Analogue Addressable Control and Indicating Equipment with User Interface - 2 Loop with Printer

2X-F2-S Intelligent Analogue Addressable Control and Indicating Equipment with User Interface - 2 Loop Small Cabinet

Incorporating the following units:

2010-2F2-MB Main control board

2X-UI User interface control board

Incorporating the following optional modules:

2X-ZI-20 (20 Zone) (Large cabinet variant only) 2X-ZI-40 (40 Zone) (Large cabinet variant only) 2X-ZI-24-S (24 Zone) (Small cabinet variant only)

2010-2-NB Network card

2X-LB Loop Board (Large cabinet variant only)
2010-2-232-KIT Interface board for external printer
2010-2-PS-C2 UK mains cable for large cabinet
2010-2-PS-C2-S UK mains cable for small cabinet

2010-2-PRT Door mounted printer module (2X-F2-PRT variant only)

2010-2-PIB-8O Peripheral Interface Board 8 outputs (Large cabinet variant only)
2010-2-PIB-8I Peripheral Interface Board 8 inputs (Large cabinet variant only)

2010-2-PIB-8I8O Peripheral Interface Board 8 outputs and 8 inputs (Large cabinet variant only)

2010-2-DACT With ATS7310 (GSM module)

2X-D-TP Translucent door option for large cabinet* (2X-F2 variant only)
2X-D-TP-S Translucent door option for small cabinet* (2X-F2-S variant only)

Date of First Issue: 23 October 2019

E Mattie-Suleiman, Certification Engineer, Date of issue: 14 March 2023

On behalf of BRE Global Assurance (Ireland) Limited Issue number: 03



Notified Body No. 2831

BRE Global Assurance (Ireland) Limited DCU Alpha, Old Finglas Road Glasnevin, Dublin, D11 KXN4 Ireland

T: +353 (0) 18824344 E: enquiries@breglobalireland.ie www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F0520

2010-FS-EOL Fault Supervision End of Line unit

2X-F2-FB2 Intelligent Analogue Addressable Control and Indicating Equipment with User Interface with Fire Brigade Controls - 2 Loop

2X-F2-FB2-PRT Intelligent Analogue Addressable Control and Indicating Equipment with User Interface with Fire Brigade Controls - 2 Loop with Printer

2X-F2-FB2-S Intelligent Analogue Addressable Control and Indicating Equipment with User Interface with Fire Brigade Controls - 2 Loop Small Cabinet

Incorporating the following units:

2010-2F2-MB Main control board

2X-UI-FB2 User interface control board

Incorporating the following optional modules:

2X-ZI-20 (20 Zone) (Large cabinet variant only)
2X-ZI-40 (40 Zone) (Large cabinet variant only)
2X-ZI-24-S (24 Zone) (Small cabinet variant only)

2010-2-NB Network card

2X-LB Loop Board (Large cabinet variant only)
2010-2-232-KIT Interface board for external printer
2010-2-PS-C2 UK mains cable for large cabinet
2010-2-PS-C2-S UK mains cable for small cabinet

2010-2-PRT Door mounted printer module (2X-F2-FB2-PRT variant only)
2010-2-PIB Peripheral Interface Board (Germany) (Large cabinet variant only)
2010-2-PIB-80 Peripheral Interface Board 8 outputs (Large cabinet variant only)
2010-2-PIB-8I Peripheral Interface Board 8 inputs (Large cabinet variant only)

2010-2-PIB-8I8O Peripheral Interface Board 8 outputs and 8 inputs (Large cabinet variant only)

ADP-N3E-U (Large cabinet variant only)
ADP-N3S (Large cabinet variant only)
2010-2-DACT With ATS7310 (GSM module)

2X-D-FB2-TP Translucent door option for large cabinet* (2X-F2-FB2 variant only)
2X-D-FB2-TP-S Translucent door option for large cabinet* (2X-F2-FB2-S variant only)

2010-FS-EOL Fault Supervision End of Line unit

Date of First Issue: 23 October 2019

E Mattie-Suleiman, Certification Engineer, Date of issue: 14 March 2023

On behalf of BRE Global Assurance (Ireland) Limited Issue number: 03



Notified Body No. 2831

BRE Global Assurance (Ireland) Limited DCU Alpha, Old Finglas Road Glasnevin, Dublin, D11 KXN4 Ireland

T: +353 (0) 18824344 E: enquiries@breglobalireland.ie www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F0520

2X-F2-SCFB Intelligent Analogue Addressable Control and Indicating Equipment with User Interface with SS3654 Fire Brigade Controls - 2 Loop with Scandinavian Key Switch

2X-F2-SCFB-S Intelligent Analogue Addressable Control and Indicating Equipment with User Interface with SS3654 Fire Brigade Controls - 2 Loop Small Cabinet with Scandinavian Key Switch

Incorporating the following units:

2010-2F2-MB Main control board

2X-UI-SCFB User interface control board

Incorporating the following optional modules:

2X-ZI-20 (20 Zone) (Large cabinet variant only) 2X-ZI-40 (40 Zone) (Large cabinet variant only)

2010-2-NB Network card

2X-LB Loop Board (Large cabinet variant only)
2010-2-232-KIT Interface board for external printer
2010-SK Scandinavian key and lock assembly
2010-2-PS-C2 UK mains cable for large cabinet
2010-2-PS-C2-S UK mains cable for small cabinet

2010-2-PIB-80 Peripheral Interface Board 8 outputs (Large cabinet variant only)
2010-2-PIB-8I Peripheral Interface Board 8 inputs (Large cabinet variant only)

2010-2-PIB-8I8O Peripheral Interface Board 8 outputs and 8 inputs (Large cabinet variant only)

2010-2-DACT With ATS7310 (GSM module)
2010-FS-EOL Fault Supervision End of Line unit

2X-E2 Intelligent Analogue Addressable Fire and Evacuation Control and Indicating Equipment with User Interface with Fire Brigade Controls - 2 Loop

2X-E2-S Intelligent Analogue Addressable Fire and Evacuation Control and Indicating Equipment with User Interface with Fire Brigade Controls - 2 Loop Small Cabinet

Incorporating the following units:

2010-2F2-MB Main control board

2X-UI-E User interface control board

Date of First Issue: 23 October 2019

E Mattie-Suleiman, Certification Engineer, Date of issue: 14 March 2023

On behalf of BRE Global Assurance (Ireland) Limited Issue number: 03



Notified Body No. 2831

BRE Global Assurance (Ireland) Limited DCU Alpha, Old Finglas Road Glasnevin, Dublin, D11 KXN4

Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F0520

Incorporating the following optional modules:

2X-ZI-20 (20 Zone) (Large cabinet variant only) 2X-ZI-40 (40 Zone) (Large cabinet variant only) 2X-ZI-24-S (24 Zone) (Small cabinet variant only)

2010-2-NB Network card

2X-LB Loop Board (Large cabinet variant only)
2010-2-232-KIT Interface board for external printer
2010-2-PS-C2 UK mains cable for large cabinet
2010-2-PS-C2-S UK mains cable for small cabinet

2010-2-PIB-80 Peripheral Interface Board 8 outputs (Large cabinet variant only)
2010-2-PIB-8I Peripheral Interface Board 8 inputs (Large cabinet variant only)

2010-2-PIB-8I8O Peripheral Interface Board 8 outputs and 8 inputs (Large cabinet variant only)

2010-2-DACT With ATS7310 (GSM module)

2X-D-E-TP Translucent door option for large cabinet*
2X-D-E-TP-S Translucent door option for large cabinet*
2010-FS-EOL Fault Supervision End of Line unit

The above fire panels are certified with the following options with requirements from EN 54-2:

7.8 Output to fire alarm device(s)

7.9.1 Output to fire alarm routing equipment (not available on 2X-F2, 2X-F2-PRT and 2X-F2-S)

- 7.9.2 Alarm confirmation input from fire alarm routing equipment (not available on 2X-F2, 2X-F2-PRT and 2X-F2-S)
- 7.10 Output to fire protection equipment Type A,B and C (not available on 2X-F2, 2X-F2-PRT and 2X-F2-S)
- 7.11 Delays to outputs
- 7.12 Dependencies on more than one alarm signal (Type A, B and C)
- 7.13 Alarm counter
- 8.4 Total loss of the power supply
- 8.9 Output to fault warning routing equipment
- 9.5 Disablement of addressable points
- 10 Test condition

Notes:

- 1. This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.
- 2. Available with the following language kit options:

Fill Date of First Issue: 23 October 2019

E Mattie-Suleiman, Certification Engineer, Date of issue: 14 March 2023

On behalf of BRE Global Assurance (Ireland) Limited Issue number: 03



Notified Body No. 2831

BRE Global Assurance (Ireland) Limited DCU Alpha, Old Finglas Road Glasnevin, Dublin, D11 KXN4 Ireland T: +353 (0) 18824344

E: enquiries@breglobalireland.ie www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F0520

01 Dutch (NL) The Netherlands, 02 French (FR), 03 English (UK) United Kingdom and Ireland, 04 German (DE) 05 Norwegian, 06 Swedish, 07 Danish (DK), 08 English (AU) Australia, 09 Spanish, 10 Italian, 11 Dutch (BE) Belgium, 12 Irish, 13 German (AU) (Austria), 14 Greek, 15 Arabic, 17 English (US) United States of America, 18 Polish, 19 Turkish, 20 Czech Republic, 21 Portuguese, 22 Hungarian, 23 Danish (IC) Iceland, 24 Slovakian, 25 Russian, 27 Lithuanian, 28 Finnish, 29 German (SW) Switzerland, 30 Estonian, 31 Latvian, 32 French (BE) Belgium, 33 French (SW) Switzerland, 34 Italian (SW) Switzerland, 36 French (Int) International, 40 Bulgarian, 41 Belarusian, 43 Ukrainian, 44 Serbian, 45 Romanian (RO), 46 German (Int) International, 48 Croatian, 49 Macedonian, 50 Slovenian, 51 Hebrew, 71 Catalan, 80 Chinese, 99 English (Int) International English

- 3. Scope of the approval does not indicate the operation of the network functionality
- 4. *The translucent door does not meet EN54-2 access level 1 requirements. To meet EN54-2 requirements with the door fitted the following is also required:
 - I. A Zone indicator board to display the zones in alarm (to meet requirements of EN54-2 part 7.3)
 - II. A MCP (without program delay) fitted beside the panel to allow overriding of delays (to meet requirements of EN54-2 part 7.11)

Date of First Issue: 23 October 2019

E Mattie-Suleiman, Certification Engineer, Date of issue: 14 March 2023

On behalf of BRE Global Assurance (Ireland) Limited Issue number: 03