

# FIRE SAFETY CERTIFICATION

## PRODUCT APPROVAL

No. **APF-1807**

**LGAI TECHNOLOGICAL CENTER S.A. (APPLUS)**, according to the requirements of the SPC-102 Ed. 5, certifies the performances stated in the technical annex following the reference standard for:



<b>Product range</b>	ZITON ZP-2 (2010-2 SERIES) FIRE DETECTION AND ALARM SYSTEM – ZITON PROTOCOL – CONFIG 2 SYSTEM
<b>Company</b>	<b>CARRIER FIRE &amp; SECURITY B.V.</b> KELVINSTRAAT, 7 6003 DH WEERT (NETHERLANDS)
<b>Manufactured</b>	<b>CARRIER FIRE &amp; SECURITY B.V.</b> KELVINSTRAAT, 7 6003 DH WEERT (NETHERLANDS)
<b>Standard Reference</b>	EN 54-13:2005 "Fire detection and fire alarm systems. Part 13: Compatibility and connectability assessment of system components".
<b>Product Details and Test Report</b>	Please check at the technical annex



**Renovation** of the initial certificate issued 16<sup>th</sup> October 2020

**Valid until 31<sup>st</sup> July 2024**

Bellaterra, 28<sup>th</sup> April 2023

 <b>Applus+</b> LGAI Technological Center, S.A. <b>Xavier Ruiz Peña</b> Product Conformity B. U., Managing Director	
You can check the validity of this certificate on our website: <a href="http://www.appluslaboratories.com/certified_products">www.appluslaboratories.com/certified_products</a>	

This document is not valid without its technical annex, whose number coincides with the number of certificate.



## APF-1807

**COMPONENTS DESCRIPTION LIST FOR ZITON ZP-2 (2010-2 SERIES)  
 FIRE DETECTION AND ALARM SYSTEM – ZITON PROTOCOL - CONFIG 2 SYSTEM  
 SYSTEM EN 54-13**

TYPE OF DEVICE	BRAND	MODEL	TYPE	EN 54 Part	FW VERSION
<b>FIRE PANELS</b>					
Addressable Fire Panel with user interface - 1 loop	ZITON	ZP2-F1 (ZP2-F1-99)	1	54-2 54-4	03.05.05.D
Addressable Fire Panel with user interface - 2 loop	ZITON	ZP2-F2 (ZP2-F2-99)	1	54-2 54-4	03.05.05.D
Addressable Fire Panel with user interface - 1 loop small cabinet	ZITON	ZP2-F1-S (ZP2-F1-S-99)	1	54-2 54-4	03.05.05.D
Addressable Fire Panel with user interface - 2 loop small cabinet	ZITON	ZP2-F2-S (ZP2-F2-S-99)	1	54-2 54-4	03.05.05.D
Addressable Fire Panel with user interface - 2 loop with printer	ZITON	ZP2-F2-PRT (ZP2-F2-PRT-99)	1	54-2 54-4	03.05.05.D
Addressable Fire Panel with user interface with fire brigade controls - 1 loop	ZITON	ZP2-F1-FB2 (ZP2-F1-FB2-99)	1	54-2 54-4	03.05.05.D
Addressable Fire Panel with user interface with fire brigade controls - 1 loop small cabinet	ZITON	ZP2-F1-FB2-S (ZP2-F1-FB2-S-99)	1	54-2 54-4	03.05.05.D
Addressable Fire Panel with user interface with fire brigade controls - 2 loop	ZITON	ZP2-F2-FB2 (ZP2-F2-FB2-99)	1	54-2 54-4	03.05.05.D
Addressable Fire Panel with user interface with fire brigade controls - 2 loop small cabinet	ZITON	ZP2-F2-FB2-S (ZP2-F2-FB2-S-99)	1	54-2 54-4	03.05.05.D
Addressable Fire Panel with user interface with fire brigade controls - 2 loop with printer	ZITON	ZP2-F2-FB2-PRT (ZP2-F2-FB2-PRT-99)	1	54-2 54-4	03.05.05.D
Addressable Fire and Evacuation Panel with user interface with fire brigade controls - 1 loop	ZITON	ZP2-E1 (ZP2-E1-99)	1	54-2 54-4	03.05.05.D
Addressable Fire and Evacuation Panel with user interface with fire brigade controls - 1 loop small cabinet	ZITON	ZP2-E1-S (ZP2-E1-S-99)	1	54-2 54-4	03.05.05.D
Addressable Fire and Evacuation Panel with user interface with fire brigade controls - 2 loop small cabinet	ZITON	ZP2-E2-S (ZP2-E2-S-99)	1	54-2 54-4	03.05.05.D

**APF-1807**

TYPE OF DEVICE	BRAND	MODEL	TYPE	EN 54 Part	FW VERSION
<b>FIRE PANELS ACCESSORIES</b>					
Addressable Fire Panel Accessory - Loop Expansion Printed Circuit Board - 2 loop	ZITON	ZP2-LB	---	---	03.00.09
Addressable Fire Panel Accessory - LED indicator - 20 zone	ZITON	ZP2-ZI-20	---	---	01.01.00
Addressable Fire Panel Accessory - LED indicator - 40 zone	ZITON	ZP2-ZI-40	---	---	01.01.00
Addressable Fire Panel Accessory - LED indicator - 24 zone	ZITON	ZP2-ZI-24-S	---	---	01.01.00
<b>REPEATERS</b>					
Addressable Fire Panel Repeater	ZITON	ZP2-FR (ZP2-FR-99)	1	54-2 54-4	03.05.05.D
Addressable Fire Panel Repeater small cabinet	ZITON	ZP2-FR-S (ZP2-FR-S-99)	1	54-2 54-4	03.05.05.D
Addressable Fire Panel Repeater with fire brigade controls	ZITON	ZP2-FR-FB2 (ZP2-FR-FB2-99)	1	54-2 54-4	03.05.05.D
Addressable Fire Panel Repeater w fire brigade controls small cabinet	ZITON	ZP2-FR-FB2-S (ZP2-FR-FB2-S-99)	1	54-2 54-4	03.05.05.D
Addressable Fire and Evacuation Panel Repeater with fire brigade controls	ZITON	ZP2-ER (ZP2-ER-99)	1	54-2 54-4	03.05.05.D
Addressable Fire and Evacuation Panel Repeater with fire brigade controls small cabinet	ZITON	ZP2-ER-S (ZP2-ER-S-99)	1	54-2 54-4	03.05.05.D
<b>MOUNTING BASES</b>					
Ziton recessed mounting base Polar White	ZITON	ZP7-RB1-P	1	EN54-1	---
Ziton surface mounting base	ZITON	ZP7-SB1 (84301/BLK)	1	EN54-1	---
Ziton surface mounting base Polar White	ZITON	ZP7-SB1-P	1	EN54-1	---
Ziton Deep base mounting Polar white	ZITON	Z-AUXD-2P	1	---	Mechanical part
<b>RELAY &amp; ISOLATOR BASES</b>					
Ziton isolator base Polar White	ZITON	ZP7-IB-P	1	EN54-17	---
Ziton isolator base Polar White	ZITON	ZP7-IB2-P	1	EN54-17	---
<b>ADDRESSABLE MANUAL CALL POINTS</b>					
Ziton red manual call point with EN54 marking (flush mount)	ZITON	ZP785-3 (172101)	1	EN54-11	---
Ziton red manual call point, weatherproof IP67 (surface mount)	ZITON	ZP787-3	1	EN54-11	---
<b>ADDRESSABLE DETECTORS</b>					
Ziton heat detector Polar White	ZITON	ZP720-3P	1	EN54-5	---
Ziton black optical smoke detector Polar White	ZITON	ZP730-2P	1	EN54-7	---
Ziton dual optical/heat detector Polar White	ZITON	ZP732-2P	1	EN54-5/7	---

## APF-1807

TYPE OF DEVICE	BRAND	MODEL	TYPE	EN 54 Part	FW VERSION
Ziton dual optical/heat detector Polar White	ZITON	ZX832-3P	1	EN54-5/7	---
Ziton dual optical/heat detector Black	ZITON	ZX832-3B	1	EN54-5/7	---
Ziton reflective beam detector 50 m	ZITON	FDR50-EZ (1109010)	1	EN54-12	---
Ziton reflective beam detector 100 m	ZITON	FDR100-EZ (1108010)	1	EN54-12	---
<b>MODULES</b>					
Ziton interface module	ZITON	A45E-2 (99202)	1	EN54-18	---
Ziton relay module	ZITON	A50E-2 (99102)	1	EN54-18	---
Ziton relay module (mains switching)	ZITON	A51E-1 (201301)	1	EN54-18	---
Ziton conventional zone module	ZITON	A70E-2 (202501-101)	1	EN54-18	---
Ziton monitored dual output module/Sounder unit	ZITON	ZP752-2 (13810-ZT)	1	EN54-18	---
Surface-mount box for A series modules, IP66 (2 single or 1 double)	ZITON	SMB-DIN1	1	EN54-1	Mechanical Part
Surface-mount box for A series modules, IP66 (4 single or 2 double)	ZITON	SMB-DIN2	1	EN54-1	Mechanical Part
Ziton enclosure for A series interfaces	ZITON	Z7-IO	1	EN 54-1	Mechanical Part
<b>ANALOGUE VISUAL INDICATORS AND BASES</b>					
Ziton white beacon with clear lens (surface mount) POLAR WHITE	ZITON	ZP755V-P	2	---	---
Ziton white base for ZP755V remote power (surface mount) Polar White	ZITON	ZP7-SBB-P	2	---	---
<b>ANALOGUE SOUNDERS BEACONS</b>					
Red sounder plug-in base	ZITON	SPB-2R	1	---	---
Polar white sounder plug-in base	ZITON	SPB-2P	1	---	---
Ziton 90 dBA base sounder (surface mount) Polar White	ZITON	ZP755B-2P	1	EN54-3	---
Ziton white 90 dBA base sounder beacon (surface mount) Polar White	ZITON	ZP755BV-4P	1	EN54-3/23	---
Ziton red cover for ZP755B base sounder with no detector	ZITON	ZP755-COV-R (70802)	1	EN54-1	---
Ziton Polar white cover for ZP755B base sounder with no detector	ZITON	ZP755-COV-P	1	EN54-1	---
Ziton red 102 dBA horn sounder with dual front/rear sound paths	ZITON	ZP755HA-2R (177601)	1	EN54-3	---
Ziton white 102 dBA horn sounder with dual front/rear sound paths	ZITON	ZP755HA-2P	1	EN54-3	---


## APF-1807

TYPE OF DEVICE	BRAND	MODEL	TYPE	EN 54 Part	FW VERSION
Ziton red 102 dBA omnidirectional sounder beacon	ZITON	ZP755HAV-2R (178001)	1	EN54-3/23	---
Ziton white 102 dBA omnidirectional sounder beacon	ZITON	ZP755HAV-2P	1	EN54-3/23	---
Ziton red 90 dBA room sounder with cover Red	ZITON	ZP755R-2R (177401)	1	EN54-3	---
ZP7 Series Addressable Weatherproof Sounder, RED	ZITON	ZP755W-2R (178601)	1	EN54-3	---
<b>ANALOGUE SOUNDERS BEACONS</b>					
Ziton weatherproof horn sounder beacon	ZITON	ZP755WV-2R (178701)	1	EN54-3/23	---



Date: 28/04/2023

## CERTIFICATE OF COMPLIANCE

This certificate of compliance validates the following			
<b>TEST REPORT NUMBER</b> 'Assessment Reports' are not acceptable	19/31703614	<b>CERTIFICATE NUMBER</b>	APF-1807
<b>DATE OF ISSUE</b>	16 <sup>th</sup> /10/2020	<b>DATE OF ISSUE</b>	28/04/2023
<b>DATE OF EXPIRY</b>	--	<b>DATE OF EXPIRY</b>	31/07/2024
Manufacturer details			
<b>NAME OF FACTORY / MANUFACTURER</b>	CARRIER FIRE & SECURITY B.V.	<b>NAME OF THE BRAND</b>	ZITON
<b>FACTORY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)</b>	KELVINSTRAAT 7, NL-6003 DH, WEERT, THE NETHERLANDS	<b>MODEL / NO</b>	ZP2 (2010-2 SERIES) FIRE DETECTION AND ALARM SYSTEM – ZITON PROTOCOL – CONFIG 2 SYSTEM
<b>WEBSITE</b>	www.carrier.com	<b>LOGO ON THE PRODUCT</b>	
<b>TEL</b>	+86 21 6331 1052	<b>EMAIL</b>	asiasales.gst@fs.utc.com





Product Details From Test Report		Reference Test Report page NO
<b>DESCRIPTION OF THE PRODUCT</b> (TECHNICAL DETAILS FROM TEST REPORT, SUCH AS ACTUAL FIRE RATINGS/DIMENSIONS/THICKNESS/ SENSITIVITY ETC)	SEE LIST BELOW	19/31703614
<b>TEST STANDARD</b> (SUCH AS ASTM/BS EN/ DN ETC)	EN 54-13:2005. Fire detection and fire alarm systems. Part 13: Compatibility assessment of system components	19/31703614
<b>TEST DESCRIPTION</b>	Construction and performance test of compatibility	19/31703614
<b>SPECIFICATION OF TEST SPECIMEN</b>	1 Fire detection and alarm system-Ziton protocol, model ZITON ZP2 (2010-2 series) Config 2 system	19/31703614
<b>TEST RESULT</b> (SUCH AS PASSED CRITERIA ___/ COMPLIED TO___/ DURATION___/OBSERVATION___/ETC)	Pass	19/31703614
<b>PRODUCT APPLICATION GUIDELINE (END USE)</b> (CLEARLY STATE THE END USE WITH SPECIFIC APPLICATION, SUCH AS EXACT FIRE RATING/TO BE INSTALLED IN___/TO BE INSTALLED AT___/TO BE CONNECTED WITH___/TO BE INSTALLED WITH___ ETC ALONG WITH ANY WARNINGS SUCH AS NOT TO BE USED IN___/NOT TO BE INSTALLED AT___/ NOT TO BE INSTALLED WITH___ ETC.	Compatibility assessment	19/31703614






Laboratory and Certification body details			
<b>NAME OF CERTIFICATION BODY</b>	Applus - LGAI Technological Center S.A.	<b>NAME OF TEST FACILITY</b>	Applus - LGAI Technological Center S.A.
<b>CERTIFICATION BODY ADDRESS / REGION</b> (STREET / TOWN / CITY / COUNTRY)	Campus UAB- Ronda de la Font del Carme s/n E-08193 Bellaterra, Barcelona, SPAIN	<b>TEST FACILITY ADDRESS / REGION</b> (STREET / TOWN / CITY / COUNTRY)	Campus UAB- Ronda de la Font del Carme s/n E-08193 Bellaterra, Barcelona, SPAIN
<b>WEBSITE</b>	www.applus.com	<b>WEBSITE</b>	www.applus.com
<b>TEL</b>	+34 93 567 20 00	<b>TEL</b>	+34 93 567 20 00
<b>EMAIL</b>	info@appluslaboratories.com	<b>EMAIL</b>	info@appluslaboratories.com
<b>ACCREDITED BY</b> (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE CERTIFICATION BODY, ALONG WITH WEBSITE)	ENAC	<b>ACCREDITED BY</b> (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE LABORATORY, ALONG WITH WEBSITE)	ENAC
<b>AS PER</b> (STANDARD TO WHICH THE CERTIFICATION BODY IS ACCREDITED TO)	EN ISO/IEC 17065	<b>AS PER</b> (STANDARD TO WHICH YOUR ORGANIZATION IS ACCREDITED TO)	EN ISO/IEC 17065
<b>VALIDITY</b> (EXPIRY DATE OF CERTIFICATION BODY ACCREDITATION)	UNLIMITED	<b>VALIDITY</b> (EXPIRY DATE OF LABORATORY ACCREDITATION)	UNLIMITED
<b>REFERENCE NUMBER:</b> (CERTIFICATION BODY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)	12/C-PR054	<b>REFERENCE NUMBER:</b> (THE LABORATORY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)	Nº 9/LE894
<b>CERTIFICATION MARK</b>			







(ENDORSEMENT) TO BE SIGNED BY MANUFACTURER			
NAME OF MANUFACTURER'S SIGNATORY	Jose Maria Mendez Segui	SIGNATURE	UTC Fire & Security España SL CL Verge de Guadalupe 3 08950. Espinades de Llobregat, Barcelona, España T: +034 93 480 90 70 F: +034 93 480 90 67
EMAIL / TEL	<a href="mailto:JoseMaria.MendezSegui@fs.utc.com">JoseMaria.MendezSegui@fs.utc.com</a> 0034 93 4809070	FACTORY OFFICIAL SEAL	NIF: B78004963  <b>UTC Fire &amp; Security</b> A United Technologies Company
<b>NOTES:</b> I Undertake that all data and information provided are genuine and accurate			

(ENDORSEMENT) TO BE SIGNED BY CERTIFICATION BODY			
NAME OF CERTIFICATION BODY SIGNATORY	Xavier Ruiz Peña	SIGNATURE	
EMAIL / TEL	<a href="mailto:xavier.ruiz@applus.com">xavier.ruiz@applus.com</a> +34 93 567 20 00	CERTIFICATION BODY OFFICIAL SEAL	LGAI Technological Center, S.A.
<b>NOTES:</b> I Undertake that all data and information provided are genuine and accurate			

**ATTACHMENTS:**

- COPY OF 'CERTIFICATE OF COMPLIANCE' ISSUED BY CERTIFICATION BODY (OLD OR NEW)

TYPE OF DEVICE	BRAND	MODEL	TYPE	EN 54 Part	FW VERSION
<b>FIRE PANELS</b>					
Addressable Fire Panel with user interface - 1 loop	ZITON	ZP2-F1 (ZP2-F1-99)	1	54-2 54-4	03.05.05.D
Addressable Fire Panel with user interface - 2 loop	ZITON	ZP2-F2 (ZP2-F2-99)	1	54-2 54-4	03.05.05.D
Addressable Fire Panel with user interface - 1 loop small cabinet	ZITON	ZP2-F1-S (ZP2-F1-S-99)	1	54-2 54-4	03.05.05.D
Addressable Fire Panel with user interface - 2 loop small cabinet	ZITON	ZP2-F2-S (ZP2-F2-S-99)	1	54-2 54-4	03.05.05.D
Addressable Fire Panel with user interface - 2 loop with printer	ZITON	ZP2-F2-PRT (ZP2-F2-PRT-99)	1	54-2 54-4	03.05.05.D
Addressable Fire Panel with user interface with fire brigade controls - 1 loop	ZITON	ZP2-F1-FB2 (ZP2-F1-FB2-99)	1	54-2 54-4	03.05.05.D
Addressable Fire Panel with user interface with fire brigade controls - 1 loop small cabinet	ZITON	ZP2-F1-FB2-S (ZP2-F1-FB2-S-99)	1	54-2 54-4	03.05.05.D
Addressable Fire Panel with user interface with fire brigade controls - 2 loop	ZITON	ZP2-F2-FB2 (ZP2-F2-FB2-99)	1	54-2 54-4	03.05.05.D





TYPE OF DEVICE	BRAND	MODEL	TYPE	EN 54 Part	FW VERSION
Addressable Fire Panel with user interface with fire brigade controls - 2 loop small cabinet	ZITON	ZP2-F2-FB2-S (ZP2-F2-FB2-S-99)	1	54-2 54-4	03.05.05.D
Addressable Fire Panel with user interface with fire brigade controls - 2 loop with printer	ZITON	ZP2-F2-FB2-PRT (ZP2-F2-FB2-PRT-99)	1	54-2 54-4	03.05.05.D
Addressable Fire and Evacuation Panel with user interface with fire brigade controls - 1 loop	ZITON	ZP2-E1 (ZP2-E1-99)	1	54-2 54-4	03.05.05.D
Addressable Fire and Evacuation Panel with user interface with fire brigade controls - 1 loop small cabinet	ZITON	ZP2-E1-S (ZP2-E1-S-99)	1	54-2 54-4	03.05.05.D
Addressable Fire and Evacuation Panel with user interface with fire brigade controls - 2 loop small cabinet	ZITON	ZP2-E2-S (ZP2-E2-S-99)	1	54-2 54-4	03.05.05.D
<b>FIRE PANELS ACCESSORIES</b>					
Addressable Fire Panel Accessory - Loop Expansion Printed Circuit Board - 2 loop	ZITON	ZP2-LB	---	---	03.00.09
Addressable Fire Panel Accessory - LED indicator - 20 zone	ZITON	ZP2-ZI-20	---	---	01.01.00
Addressable Fire Panel Accessory - LED indicator - 40 zone	ZITON	ZP2-ZI-40	---	---	01.01.00
Addressable Fire Panel Accessory - LED indicator - 24 zone	ZITON	ZP2-ZI-24-S	---	---	01.01.00
<b>REPEATERS</b>					
Addressable Fire Panel Repeater	ZITON	ZP2-FR (ZP2-FR-99)	1	54-2 54-4	03.05.05.D
Addressable Fire Panel Repeater small cabinet	ZITON	ZP2-FR-S (ZP2-FR-S-99)	1	54-2 54-4	03.05.05.D
Addressable Fire Panel Repeater with fire brigade controls	ZITON	ZP2-FR-FB2 (ZP2-FR-FB2-99)	1	54-2 54-4	03.05.05.D
Addressable Fire Panel Repeater w fire brigade controls small cabinet	ZITON	ZP2-FR-FB2-S (ZP2-FR-FB2-S-99)	1	54-2 54-4	03.05.05.D
Addressable Fire and Evacuation Panel Repeater with fire brigade controls	ZITON	ZP2-ER (ZP2-ER-99)	1	54-2 54-4	03.05.05.D
Addressable Fire and Evacuation Panel Repeater with fire brigade controls	ZITON	ZP2-ER-S (ZP2-ER-S-99)	1	54-2 54-4	03.05.05.D





TYPE OF DEVICE	BRAND	MODEL	TYPE	EN 54 Part	FW VERSION
small cabinet					
<b>MOUNTING BASES</b>					
Ziton recessed mounting base Polar White	ZITON	ZP7-RB1-P	1	EN54-1	---
Ziton surface mounting base	ZITON	ZP7-SB1 (84301/BLK)	1	EN54-1	---
Ziton surface mounting base Polar White	ZITON	ZP7-SB1-P	1	EN54-1	---
Ziton Deep base mounting Polar white	ZITON	Z-AUXD-2P	1	---	Mechanical part
<b>RELAY &amp; ISOLATOR BASES</b>					
Ziton isolator base Polar White	ZITON	ZP7-IB-P	1	EN54-17	---
Ziton isolator base Polar White	ZITON	ZP7-IB2-P	1	EN54-17	---
<b>ADDRESSABLE MANUAL CALL POINTS</b>					
Ziton red manual call point with EN54 marking (flush mount)	ZITON	ZP785-3 (172101)	1	EN54-11	---
Ziton red manual call point, weatherproof IP67 (surface mount)	ZITON	ZP787-3	1	EN54-11	---
<b>ADDRESSABLE DETECTORS</b>					
Ziton heat detector Polar White	ZITON	ZP720-3P	1	EN54-5	---
Ziton black optical smoke detector Polar White	ZITON	ZP730-2P	1	EN54-7	---
Ziton dual optical/heat detector Polar White	ZITON	ZP732-2P	1	EN54-5/7	---
Ziton dual optical/heat detector Polar White	ZITON	ZX832-3P	1	EN54-5/7	---
Ziton dual optical/heat detector Black	ZITON	ZX832-3B	1	EN54-5/7	---
Ziton reflective beam detector 50 m	ZITON	FDR50-EZ (1109010)	1	EN54-12	---
Ziton reflective beam detector 100 m	ZITON	FDR100-EZ (1108010)	1	EN54-12	---
<b>MODULES</b>					
Ziton interface module	ZITON	A45E-2 (99202)	1	EN54-18	---
Ziton relay module	ZITON	A50E-2 (99102)	1	EN54-18	---
Ziton relay module (mains switching)	ZITON	A51E-1 (201301)	1	EN54-18	---
Ziton conventional zone module	ZITON	A70E-2 (202501-101)	1	EN54-18	---
Ziton monitored dual output module/Sounder unit	ZITON	ZP752-2 (13810-ZT)	1	EN54-18	---
Surface-mount box for A	ZITON	SMB-DIN1	1	EN54-1	Mechanical Part





TYPE OF DEVICE	BRAND	MODEL	TYPE	EN 54 Part	FW VERSION
series modules, IP66 (2 single or 1 double)					
Surface-mount box for A series modules, IP66 (4 single or 2 double)	ZITON	SMB-DIN2	1	EN54-1	Mechanical Part
Ziton enclosure for A series interfaces	ZITON	Z7-IO	1	EN 54-1	Mechanical Part
<b>ANALOGUE VISUAL INDICATORS AND BASES</b>					
Ziton white beacon with clear lens (surface mount) POLAR WHITE	ZITON	ZP755V-P	2	---	---
Ziton white base for ZP755V remote power (surface mount) Polar White	ZITON	ZP7-SBB-P	2	---	---
<b>ANALOGUE SOUNDERS BEACONS</b>					
Red sounder plug-in base	ZITON	SPB-2R	1	---	---
Polar white sounder plug-in base	ZITON	SPB-2P	1	---	---
Ziton 90 dBA base sounder (surface mount) Polar White	ZITON	ZP755B-2P	1	EN54-3	---
Ziton white 90 dBA base sounder beacon (surface mount) Polar White	ZITON	ZP755BV-4P	1	EN54-3/23	---
Ziton red cover for ZP755B base sounder with no detector	ZITON	ZP755-COV-R (70802)	1	EN54-1	---
Ziton Polar white cover for ZP755B base sounder with no detector	ZITON	ZP755-COV-P	1	EN54-1	---
Ziton red 102 dBA horn sounder with dual front/rear sound paths	ZITON	ZP755HA-2R (177601)	1	EN54-3	---
Ziton white 102 dBA horn sounder with dual front/rear sound paths	ZITON	ZP755HA-2P	1	EN54-3	---
Ziton red 102 dBA omnidirectional sounder beacon	ZITON	ZP755HAV-2R (178001)	1	EN54-3/23	---
Ziton white 102 dBA omnidirectional sounder beacon	ZITON	ZP755HAV-2P	1	EN54-3/23	---
Ziton red 90 dBA room sounder with cover Red	ZITON	ZP755R-2R (177401)	1	EN54-3	---
ZP7 Series Addressable Weatherproof Sounder, RED	ZITON	ZP755W-2R (178601)	1	EN54-3	---
<b>ANALOGUE SOUNDERS BEACONS</b>					
Ziton weatherproof horn sounder beacon	ZITON	ZP755WV-2R (178701)	1	EN54-3/23	---

