



INCERT CERTIFICATE C-001-1702



Issued 07-05-2024 Replaces
Expiry date 13-02-2026 Page 1 / 4

In compliance with the procedure specified in the **INCERT Scheme (Doc. Nr 005)**, Kiwa FSS products declares that the stated alarm equipment complies with the Technical standards and specifications as listed in this certificate.

Product description: UltraSync Communicator with IP and 4G/2G dual path suitable for both fire and intrusion panels
Trademark: Aritech
Type designation: UC-240(SW)
Hardware / Software: 207370PB04 / A71P000026-07
Variants: See Annex 3

Placed on the market under the name or trademark of:

Name of the manufacturer: Carrier Fire & Security B.V.
Address: Kelvinstraat 7
City: 6003DH Weert
Country: Netherlands

This certificate is granted to:

Name of the certificate holder: Carrier Fire & Security EMEA bvba
Address: De Kleetlaan 3
City: 1831 Diegem
Country: Belgium

Ron Scheepers
Managing director

This INCERT Certificate has THREE Annexes and is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standards. It does not imply an assessment on the whole production. Conformity of the produced products with the specimen tested remains on the fully responsibility of the manufacturer.

Kiwa Nederland B.V.
Kiwa FSS Products
Wilmsdorf 50
Postbus 137
7300 AC Apeldoorn
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>



CERTIFICATE

Remarks and observations

The following conditions are applicable:

Category: Transmitter

Security grade: 2, UC-140(SW)

Security grade: 3, UC-240(SW)

Environmental class: II

Equipment class: Fixed

SPT structure: Type Y

ATS category: SP2 (UC-140(SW)); DP2/DP3 (UC-240(SW))

Factory location:

Dong Guan Elma Electronics Co., Ltd.

No.7, Yin Hu Industrial District, Giao E Tang, Tang Xia Town

Dong Guan

China

Product inspection location:

Carrier Fire & Security B.V.

Kelvinstraat 7

Weert

Netherlands

Documentation lodged for this INCERT certificate

Test Reports:

- Kiwa Nederland B.V.: P000311795-001-Ver1.00, 27 September 2023
- BRE Global Ltd: P114527A Issue: 2, 06 July 2021
- BRE Global Ltd: P114527B Issue: 2, 06 July 2021
- BRE Global Ltd: P119390A Issue: 3, 22 February 2022
- BRE Global Ltd: P126467A Issue: 2, 15 January 2024
- BRE Global Ltd: P126467C Issue: 2, 15 January 2024

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Mechanical drawings
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

T 031+A1+A2 August, 2022

Applied Standards

EN 50130-5	June, 2011
EN 50136-2	August, 2013
EN 50131-10	June, 2014
EN 50130-4+A1	October, 2014
EN 50136-1+A1	November, 2018
EN 50131-1+A1+A2+A3	June, 2020

The product as described in this certificate includes the following type designations

- Product description: UltraSync Communicator with IP and 4G/2G dual path suitable for both fire and intrusion panels
- Trademark: Aritech
- Type designation: UC-240(SW)
- Hardware version: 207370PB04
- Software version: A71P000026-07

- Product description: UltraSync Communicator with 4G/2G single path suitable for Intrusion panels
- Trademark: Aritech
- Type designation: UC-140(SW)
- Hardware version: 207370PB04
- Software version: A71P000026-07