2010-2-PAK-RMSDK

2010-2 PAK Enables custom event reporting and command control using the Edwards

Overview

The fire panel allows for its capabilities to be extended by use of USB dongles. These USB dongles are called PAK, which stands for Panel Activation Key. The use of the PAK will activate additional high-end feature(s) in the panel. Depending on the required functionality, separate and multiple PAKs can be used to enable these functionalities. Functionalities like number of nodes/loops, supported detector protocol, used TCP/IP communication protocol for remote monitoring, communication towards management software like BACNet or Modbus, etc, can be enabled by usage of the PAKs. The PAK is tied to the serial number of the panel, but does not have to stay connected to the panel. It can be removed once the PAK has been installed, and the feature is enabled in the panel. It is therefore recommend that PAKs stays with the panel at all time, for example in case of performing reset functions or re-installations.



Détails

- Enables custom event reporting and command control using the Edwards software development kit (SDK)
- Compatible with panel firmware 3.1. or higher

2010-2-PAK-RMSDK

2010-2 PAK Enables custom event reporting and command control using the Edwards

Spécifications techniques

Général

Compatibilité	USB type 2.0

Caractéristiques physiques

Types de format	Petit
Dimensions physiques	22 x 70 x 5 mm (W x H x D)
Poids net	75 g
Poids à l'expédition	120 g
Type de montage	En armoire

Environnement

Température de fonctionnement	-5 to +40°C
Température de stockage	-20 to +50°C
Humidité relative	Max. 95% noncondensing

Régulateur

Certification	EN54-13, EN54-2
Normes	EN54-2 EN54-13
Environnement	CPD WEEE RoHS

En tant que société d'innovation, Kidde Global Solutions se réserve le droit de modifier les spécifications des produits sans préavis. Pour les dernières spécifications du produit, visitez le site web be.firesecurityproducts.com ou contactez votre représentant commercial.

Last updated on 1 September 2025 - 15:04