GS331

Test Unit for Piezo glassbreak detectors

Glass Break Tester

The tester GS331 is used to verify the operation of the glued-on-glass glass break detectors GS300/310. You test the detector by pressing the tester against the window. A noise will be heard simulating a glass breakage. It is recommended to test the glass break detectors before and after the installation.

Please note that this is not a range tester.



Détails

- Automatic switching off
- Battery display via LED
- Test display via LED

GS331

Test Unit for Piezo glassbreak detectors

Spécifications techniques

Général

Groupe d'accessoires	Détecteurs de bris de glace
Type	Pièce de rechange

Électrique

Type de bloc d’alimentation	Batteries
Valeur de l'alimentation	9 V battery
Tension de fonctionnement	6 to 10 VDC
Consommation de courant	1 mA nominal at 12 VDC (standby) 60 mA nominal at 12 V (alarm)
Battery capacity	Approx. 8 h operating time or 3000 activities (each 10 s)

Caractéristiques physiques

Dimensions physiques	120 x 60 x25 mm
Poids net	150 g

General

System indicator	Green LED blinks at pushed button mode
Battery indicator	Red LED

En tant que société d'innovation, Kidde Global Solutions se réserve le droit de modifier les spécifications des produits sans préavis. Pour les dernières spécifications du produit, visitez le site web be.firesecurityproducts.com ou contactez votre représentant commercial.

Last updated on 18 June 2026 - 14:24