KM303

Carbon Monoxide Control Panel for Car Parks - 3 Zones

The KM303 is a 3 Zone Carbon Monoxide (CO) detection control panel designed for applications where concentrations of CO may accumulate and needs to be controlled in order to protect lives. The panel is able to accommodate 3 supervised detection zone using KMD300 CO detectors.The panel is compliant with UNE 23-301-88, CE, WEEE and RoHS.



Détails

- Elegant design
- 3 Supervised CO detection zone
- Easy to install and to use
- Language customisation using language inserts
- Clear and accurate display of CO levels per zone
- Up to 15 detectors per zone
- Fast response times
- Extraction and alarm outputs per zone
- Supervision of all CO detectors and zones
- Using surface mount technology with low current consumption
- Compatible with KMD300 CO detectors
- UNE 23300:1984, CE, WEEE and RoHS compliant
- External and internal power supply support

KM303

Carbon Monoxide Control Panel for Car Parks - 3 Zones

Spécifications techniques

Électrique

Tension de fonctionnement	230 VAC ±10% 50 Hz

Zone

Tension de fonctionnement	10 to 20 VDC (input)
Quantité de dispositifs par zone	15 max.
Évaluation	1 A max. (supply current)
Cote de câble	3 core 1.5 mm², 350 m max.
CO Sensitivity	0 to 300 ppm

Caractéristiques physiques

Dimensions physiques	297 x 307 x 109 mm (W x H x D)
Poids net	3 kg
Type de montage	Montage en surface
Entrées de câble	4 x 20 mm (Ø, top)

Environnement

Température de fonctionnement	0 to +40°C
Température de stockage	-10 to +70°C
Humidité relative	10 to 95% noncondensing

Output

No. of relays per zone	3
Relay contact rating	5 A at 30 VDC or 8 A at 250 VAC
Relay switching power	150 W max.

Produits compatibles

Catégorie	Référence	Description
Module de détection	KMD300	

En tant que société d'innovation, Kidde Global Solutions se réserve le droit de modifier les spécifications des produits sans préavis. Pour les dernières spécifications du produit, visitez le site web be.firesecurityproducts.com ou contactez votre représentant commercial.

Last updated on 4 June 2025 - 15:29